



Portable Fire Extinguisher Inspection Checklist Rechargeable Type (ABC)

Monthly inspection shall include a check of at least the following:

- Located in designated place, visible and with signage.
- Hung on a bracket.
- Positioned at a height no higher than four feet.
- No obstruction to access or visibility.
- Operating instructions on nameplate are legible.
- Safety seals and tamper indicators not broken or missing.
- Examined for obvious physical damage, corrosion, leakage, or clogged nozzle.
- Pressure gauge reading or indicator in the operable range or position.
- For wheeled units, the condition of the tires, wheels, carriage, hose, and nozzle checked.
- Service company tag attached, signed and dated (annual).
- Nozzle free and clear of debris.
- To avoid injury, it is recommended you do not lift extinguishers upside down on your inspections to loosen powder. Your fire protection provider will do this on their annual inspection.

Corrective Action:

When an inspection of a fire extinguisher reveals a deficiency in any of the conditions listed above, immediate corrective action should be taken.

- Keep records of inspections.

Inspections:

Monthly Inspection	Internal
Annual Inspection	Fire Protection Company
Six-Year Service	Fire Protection Company
Twelve-Year Hydro Test	Fire Protection Company