



Portable Fire Extinguishers Inspection Checklist Rechargeable Type (CO2)

Company Name: _____

Monthly Inspections:

Shall include a check of at least the following;

1. located in designated place
2. tagged, dated and signed by fire protection provider (within current year)
3. no obstructions to access or visibility
4. nameplate legible and facing outward
5. safety seal and tamper indicators not broken or missing
6. fullness determined by weighing cylinder – (speak to your fire protection company for specific requirements to determine weight)
7. examined for obvious physical damage, corrosion, leakage, or clogged nozzle

NOTE:

When an inspection of a fire extinguisher reveals a deficiency in any of the conditions listed above, report it to your safety representative so **immediate** corrective action can be taken.

Monthly Inspection – Internal

Annual Inspection
Fire Protection Company

5-year Inspection
Fire Protection Company